

Clean & Disinfection Certificate

DATE OF ISSUE:	18 th November 2024
CLIENT:	The Pioneer Group
SITE:	Chivenor House
WORK COMPLETED BY:	Stephen Preece
JOB NUMBER:	n/a
HUB NUMBER:	703188

Location/Description of system

DATE OF SITE WORK:	18th November 2024
SYSTEM TYPE:	C&D of 1 x CWST
SYSTEM LOCATION:	Basement
CHEMICAL LEVELS:	50ppm
CONTACT TIME:	1 Hour

We hereby confirm that on the date shown, the above detailed systems were disinfected to BS PD 855468:2015.

Date of Issue:	When required.
Additional observations and recommendations	
1 x 6,000 Ltr CWST cleaned and disinfection as requested.	

~This Certificate should be added to the System Log Book~



